

Annex-12



OFFICE OF THE DEPUTY FIRE OFFICER
ANGUL CIRCLE, ANGUL

FORM-V

FIRE SAFETY CERTIFICATE

(See rule-13 (3) of the Odisha Fire Prevention and Fire Safety Rules, 2017)

File No-A-01-2017 (Edu.)

Certificate No.07/2020/Agl. Circle

Dated-26.02.2020

This certificate is valid up to 25.02.2022

(Apply for renewal at least three months before expiry)

Certified that Sankha Jyoti Public School, over Plot No-2822/3022, Khata No.266/251, At- Vidya Vihar, Khindo, PO- Kuluma, PS- Rengali Dam Site, Dist.- Angul consisting of total one block was inspected by officers of Odisha Fire Service on 25.02.2020 in presence of Smt. Tapaswini Behera, Principal & Staff of Sankha Jyoti Public School and it has been found to comply with the Fire Prevention and Fire Safety requirements in accordance with Odisha Fire Prevention and Fire Safety Rules, 2017 and that its various floors are fit for occupancy or usage as noted hereunder against each subject to compliance to the conditions as prescribed herein below:-

1	Ground to 1 st floor (01 block)	---Usage---	Educational
---	--	-------------	-------------

CONDITIONS:-

1. Fire prevention and safety measures and appliances, availability of water supplies and means of access thereto etc. provided in the building or premises, should be maintained by the occupier(s) in best repairs and efficient working condition at all times for use by the occupants or the members of the Fire Service or both in the event of outbreak of fire.
2. The set-backs, driveways, entrance gates, exists, staircases, corridors, and escape ways should not be changed, obstructed or modified in any way.
3. The occupier(s) shall train all staff and occupants periodically to make them well conversant in use and operation of the fire prevention and safety measures.
4. Fire Drills / rehearsals should be organized at least once in six months by involving local fire station.
5. Photocopies of this Certificate should be framed and displayed at all conspicuous places in all lobbies/corridors in all floors of all towers / blocks of building/ premises.

T. Behera

Chandra Mohan Rautray
26/2/20
(Chandra Mohan Rautray)
Deputy Fire Officer
Angul Circle, Angul

Deputy Fire Officer
Angul Circle, Angul